

NORTH POOL

**NOTICE: Bids will now be accepted via email only to jordanh@superiorcolorado.gov
 Bids will not be opened before the deadline. Please submit one PDF of complete bid package and one Bid Schedule in excel format.**

RFI #	Sheet	Question / Clarification	Architect / Engineer response
3		SECURITY/FIRE ALARM Who is the town security vendor and contact for the Fire Alarm vendor per note 2 on page E402?	The intent behind keynote 2 on E401 for the North Pool was to provide a new device for a thermal detector and smoke detector (existing devices in the pool mechanical room) in the new aux. mechanical building to match what the room currently has now. Similarly for the South Pool, new devices should be provided in similar locations to where they are now.