

## SOUTH POOL

RFI #	Sheet	Question / Clarification	Architect / Engineer response	Response by
74		RFI Response to question #39 says to provide a separate line item under section 03 Concrete on the bid form. If we create a separate line item on the bid form, it will carry that unit price in our base bid and skew our base bid total. Is there another option to provide you a unit cost for shade structure foundations?	Please provide pricing for the footing design as shown in detail 4/L300. No unit cost of concrete is required. There may be adjustments to this footer detail once engineering calcs & shop drawings are received from the shade manufacturer, i.e. number and size of anchor bolts. No separate line item under Division 03 is needed.	BRS
75				
76				
77				
78				
79				
80				
81				
82				
83				
84				
85				
86				
87				
88				
89				
90				
91				